

ネポン株式会社

【ハウスカナンキ 0.1,3型シリーズ】1/2

2015年度 (平成 27 年度) 熱効率率/燃料消費量 経年変化一覧表

製品シリーズ	製造開始年	製造終了年	製品型式	熱出力		燃料消費量 (l/h)	熱効率	燃料	標準暖房面積 (a)	製造年度別 経年変化による現在の熱効率および燃料消費量															
				(kcal/h)	(kW)					1965		1966		1967		1968		1969		1970		1971			
										%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)		
0型	1965 (S40)	1976 (S51)	HK150TE	32,000	37.2	4.6	80%	A重油	2.3~5.0	69.0%	5.3	69.3%	5.3	69.5%	5.3	69.7%	5.2	69.9%	5.2	70.1%	5.2	70.4%	5.2		
			HK150SE	32,000	37.2	4.6	80%	A重油	2.3~5.0	69.0%	5.3	69.3%	5.3	69.5%	5.3	69.7%	5.2	69.9%	5.2	70.1%	5.2	70.4%	5.2		
			HK300TE	75,000	87.2	10.7	80%	A重油	6.6~9.9	69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2	70.1%	12.2	70.4%	12.2		
			HK300TC	75,000	87.2	10.7	80%	A重油	6.6~9.9	69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2	70.1%	12.2	70.4%	12.2		
			HK300SE	75,000	87.2	10.7	80%	A重油	6.6~9.9	69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2	70.1%	12.2	70.4%	12.2		
			HK300SC	75,000	87.2	10.7	80%	A重油	6.6~9.9	69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2	70.1%	12.2	70.4%	12.2		
			HK400TE	87,000	101	12.3	80%	A重油	9.9~13.2	69.0%	14.4	69.3%	14.3	69.5%	14.3	69.7%	14.2	69.9%	14.2	70.1%	14.1	70.4%	14.1		
			HK400TC	87,000	101	12.3	80%	A重油	9.9~13.2	69.0%	14.4	69.3%	14.3	69.5%	14.3	69.7%	14.2	69.9%	14.2	70.1%	14.1	70.4%	14.1		
			HK500TC	125,000	145	17.8	80%	A重油	13.2~16.5	69.0%	20.6	69.3%	20.6	69.5%	20.5	69.7%	20.4	69.9%	20.4	70.1%	20.3	70.4%	20.3		
HK600TC	150,000	174	21.3	80%	A重油	16.5~19.8	69.0%	24.8	69.3%	24.7	69.5%	24.6	69.7%	24.5	69.9%	24.5	70.1%	24.4	70.4%	24.3					
1型	1971 (S46)	1978 (S53)	HK301TE	75,000	87.2	10.7	80%	A重油	6.6~9.9													70.4%	12.2		
			HK301TC	75,000	87.2	10.7	80%	A重油	6.6~9.9														70.4%	12.2	
			HK401TE	87,000	101	12.3	80%	A重油	9.9~13.2														70.4%	14.1	
			HK401TC	87,000	101	12.3	80%	A重油	9.9~13.2															70.4%	14.1
			HK501TC	125,000	145	17.8	80%	A重油	13.2~16.5															70.4%	20.3
			HK601TC	150,000	174	21.3	80%	A重油	16.5~19.8																70.4%
現行機種 (機器熱効率率 90%) へ更新した場合の経年変化節減率 ※同等熱出力換算									23.3%	23.0%	22.8%	22.6%	22.3%	22.1%	21.8%										

【ハウスカナンキ 0.1,3型シリーズ】2/2

製品シリーズ	製造開始年	製造終了年	製品型式	熱出力		燃料消費量 (l/h)	熱効率	燃料	標準暖房面積 (a)	製造年度別 経年変化による現在の熱効率および燃料消費量														
				(kcal/h)	(kW)					1972		1973		1974		1975		1976		1977		1978		
										%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	
0型	1965 (S40)	1976 (S51)	HK150TE	32,000	37.2	4.6	80%	A重油	2.3~5.0	70.6%	5.2	70.8%	5.2	71.0%	5.1	71.2%	5.1	71.5%	5.1					
			HK150SE	32,000	37.2	4.6	80%	A重油	2.3~5.0	70.6%	5.2	70.8%	5.2	71.0%	5.1	71.2%	5.1	71.5%	5.1					
			HK300TE	75,000	87.2	10.7	80%	A重油	6.6~9.9	70.6%	12.1	70.8%	12.1	71.0%	12.0	71.2%	12.0	71.5%	12.0					
			HK300TC	75,000	87.2	10.7	80%	A重油	6.6~9.9	70.6%	12.1	70.8%	12.1	71.0%	12.0	71.2%	12.0	71.5%	12.0					
			HK300SE	75,000	87.2	10.7	80%	A重油	6.6~9.9	70.6%	12.1	70.8%	12.1	71.0%	12.0	71.2%	12.0	71.5%	12.0					
			HK300SC	75,000	87.2	10.7	80%	A重油	6.6~9.9	70.6%	12.1	70.8%	12.1	71.0%	12.0	71.2%	12.0	71.5%	12.0					
			HK400TE	87,000	101	12.3	80%	A重油	9.9~13.2	70.6%	14.1	70.8%	14.0	71.0%	14.0	71.2%	13.9	71.5%	13.9					
			HK400TC	87,000	101	12.3	80%	A重油	9.9~13.2	70.6%	14.1	70.8%	14.0	71.0%	14.0	71.2%	13.9	71.5%	13.9					
			HK500TC	125,000	145	17.8	80%	A重油	13.2~16.5	70.6%	20.2	70.8%	20.1	71.0%	20.1	71.2%	20.0	71.5%	19.9					
HK600TC	150,000	174	21.3	80%	A重油	16.5~19.8	70.6%	24.2	70.8%	24.2	71.0%	24.1	71.2%	24.0	71.5%	23.9								
1型	1971 (S46)	1978 (S53)	HK301TE	75,000	87.2	10.7	80%	A重油	6.6~9.9	70.6%	12.1	70.8%	12.1	71.0%	12.0	71.2%	12.0	71.5%	12.0	71.7%	11.9	71.9%	11.9	
			HK301TC	75,000	87.2	10.7	80%	A重油	6.6~9.9	70.6%	12.1	70.8%	12.1	71.0%	12.0	71.2%	12.0	71.5%	12.0	71.7%	11.9	71.9%	11.9	
			HK401TE	87,000	101	12.3	80%	A重油	9.9~13.2	70.6%	14.1	70.8%	14.0	71.0%	14.0	71.2%	13.9	71.5%	13.9	71.7%	13.8	71.9%	13.8	
			HK401TC	87,000	101	12.3	80%	A重油	9.9~13.2	70.6%	14.1	70.8%	14.0	71.0%	14.0	71.2%	13.9	71.5%	13.9	71.7%	13.8	71.9%	13.8	
			HK501TC	125,000	145	17.8	80%	A重油	13.2~16.5	70.6%	20.2	70.8%	20.1	71.0%	20.1	71.2%	20.0	71.5%	19.9	71.7%	19.9	71.9%	19.8	
			HK601TC	150,000	174	21.3	80%	A重油	16.5~19.8	70.6%	24.2	70.8%	24.2	71.0%	24.1	71.2%	24.0	71.5%	23.9	71.7%	23.9	71.9%	23.8	
3型	1974 (S49)	1978 (S53)	HK303TE	75,000	87.2	10.7	80%	A重油	6.6~9.9					71.0%	12.0	71.2%	12.0	71.5%	12.0	71.7%	11.9	71.9%	11.9	
			HK303TC	75,000	87.2	10.7	80%	A重油	6.6~9.9					71.0%	12.0	71.2%	12.0	71.5%	12.0	71.7%	11.9	71.9%	11.9	
			HK403TE	87,000	101	12.3	80%	A重油	9.9~13.2					71.0%	14.0	71.2%	13.9	71.5%	13.9	71.7%	13.8	71.9%	13.8	
			HK403TC	87,000	101	12.3	80%	A重油	9.9~13.2					71.0%	14.0	71.2%	13.9	71.5%	13.9	71.7%	13.8	71.9%	13.8	
現行機種 (機器熱効率率 90%) へ設備更新した場合の経年変化分 燃料消費節減率 ※同等熱出力換算									21.6%	21.3%	21.1%	20.9%	20.6%	20.4%	20.1%									