

ネポン株式会社

【ハウスカマキ 0.1.3型シリーズ】1/2 2013年度 (平成 25 年度) 熱効率/燃料消費量 経年変化一覧表

製品 シリーズ	製造 開始年	製造 終了年	製品型式	熱出力		燃料 消費量 (l/h)	熱効率	燃料	標準暖房 面積 (a)	製造年度別 経年変化による現在の熱効率および燃料消費量																			
				(kcal/h)	(kW)					1965		1966		1967		1968		1969		1970		1971							
										%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)						
O型	1965 (S40)	1976 (S51)	HK150TE	32,000	37.2	4.6	80%	A重油	2.3~5.0	69.5%	5.3	69.7%	5.2	69.9%	5.2	70.1%	5.2	70.4%	5.2	70.6%	5.2	70.8%	5.2						
			HK150SE	32,000	37.2	4.6	80%	A重油	2.3~5.0	69.5%	5.3	69.7%	5.2	69.9%	5.2	70.1%	5.2	70.4%	5.2	70.6%	5.2	70.8%	5.2						
			HK300TE	75,000	87.2	10.7	80%	A重油	6.6~9.9	69.5%	12.3	69.7%	12.3	69.9%	12.2	70.1%	12.2	70.4%	12.2	70.6%	12.1	70.8%	12.1						
			HK300TC	75,000	87.2	10.7	80%	A重油	6.6~9.9	69.5%	12.3	69.7%	12.3	69.9%	12.2	70.1%	12.2	70.4%	12.2	70.6%	12.1	70.8%	12.1						
			HK300SE	75,000	87.2	10.7	80%	A重油	6.6~9.9	69.5%	12.3	69.7%	12.3	69.9%	12.2	70.1%	12.2	70.4%	12.2	70.6%	12.1	70.8%	12.1						
			HK300SC	75,000	87.2	10.7	80%	A重油	6.6~9.9	69.5%	12.3	69.7%	12.3	69.9%	12.2	70.1%	12.2	70.4%	12.2	70.6%	12.1	70.8%	12.1						
			HK400TE	87,000	101	12.3	80%	A重油	9.9~13.2	69.5%	14.3	69.7%	14.2	69.9%	14.2	70.1%	14.1	70.4%	14.1	70.6%	14.1	70.8%	14.0						
			HK400TC	87,000	101	12.3	80%	A重油	9.9~13.2	69.5%	14.3	69.7%	14.2	69.9%	14.2	70.1%	14.1	70.4%	14.1	70.6%	14.1	70.8%	14.0						
			HK500TC	125,000	145	17.8	80%	A重油	13.2~16.5	69.5%	20.5	69.7%	20.4	69.9%	20.4	70.1%	20.3	70.4%	20.3	70.6%	20.2	70.8%	20.1						
HK600TC	150,000	174	21.3	80%	A重油	16.5~19.8	69.5%	24.6	69.7%	24.5	69.9%	24.5	70.1%	24.4	70.4%	24.3	70.6%	24.2	70.8%	24.2									
1型	1971 (S46)	1978 (S53)	HK301TE	75,000	87.2	10.7	80%	A重油	6.6~9.9														70.8%	12.1					
			HK301TC	75,000	87.2	10.7	80%	A重油	6.6~9.9																70.8%	12.1			
			HK401TE	87,000	101	12.3	80%	A重油	9.9~13.2																	70.8%	14.0		
			HK401TC	87,000	101	12.3	80%	A重油	9.9~13.2																		70.8%	14.0	
			HK501TC	125,000	145	17.8	80%	A重油	13.2~16.5																			70.8%	20.1
			HK601TC	150,000	174	21.3	80%	A重油	16.5~19.8																				70.8%
現行機種 (機器熱効率 90%) へ更新した場合の 経年変化節減率 ※同等熱出力換算									22.8%		22.6%		22.3%		22.1%		21.8%		21.6%		21.3%								

【ハウスカマキ 0.1.3型シリーズ】2/2

製品 シリーズ	製造 開始年	製造 終了年	製品型式	熱出力		燃料 消費量 (l/h)	熱効率	燃料	標準暖房 面積 (a)	製造年度別 経年変化による現在の熱効率および燃料消費量															
				(kcal/h)	(kW)					1972		1973		1974		1975		1976		1977		1978			
										%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)		
O型	1965 (S40)	1976 (S51)	HK150TE	32,000	37.2	4.6	80%	A重油	2.3~5.0	71.0%	5.1	71.2%	5.1	71.5%	5.1	71.7%	5.1	71.9%	5.1						
			HK150SE	32,000	37.2	4.6	80%	A重油	2.3~5.0	71.0%	5.1	71.2%	5.1	71.5%	5.1	71.7%	5.1	71.9%	5.1						
			HK300TE	75,000	87.2	10.7	80%	A重油	6.6~9.9	71.0%	12.0	71.2%	12.0	71.5%	12.0	71.7%	11.9	71.9%	11.9						
			HK300TC	75,000	87.2	10.7	80%	A重油	6.6~9.9	71.0%	12.0	71.2%	12.0	71.5%	12.0	71.7%	11.9	71.9%	11.9						
			HK300SE	75,000	87.2	10.7	80%	A重油	6.6~9.9	71.0%	12.0	71.2%	12.0	71.5%	12.0	71.7%	11.9	71.9%	11.9						
			HK300SC	75,000	87.2	10.7	80%	A重油	6.6~9.9	71.0%	12.0	71.2%	12.0	71.5%	12.0	71.7%	11.9	71.9%	11.9						
			HK400TE	87,000	101	12.3	80%	A重油	9.9~13.2	71.0%	14.0	71.2%	13.9	71.5%	13.9	71.7%	13.8	71.9%	13.8						
			HK400TC	87,000	101	12.3	80%	A重油	9.9~13.2	71.0%	14.0	71.2%	13.9	71.5%	13.9	71.7%	13.8	71.9%	13.8						
			HK500TC	125,000	145	17.8	80%	A重油	13.2~16.5	71.0%	20.1	71.2%	20.0	71.5%	19.9	71.7%	19.9	71.9%	19.8						
HK600TC	150,000	174	21.3	80%	A重油	16.5~19.8	71.0%	24.1	71.2%	24.0	71.5%	23.9	71.7%	23.9	71.9%	23.8									
1型	1971 (S46)	1978 (S53)	HK301TE	75,000	87.2	10.7	80%	A重油	6.6~9.9	71.0%	12.0	71.2%	12.0	71.5%	12.0	71.7%	11.9	71.9%	11.9	72.1%	11.9	72.3%	11.8		
			HK301TC	75,000	87.2	10.7	80%	A重油	6.6~9.9	71.0%	12.0	71.2%	12.0	71.5%	12.0	71.7%	11.9	71.9%	11.9	72.1%	11.9	72.3%	11.8		
			HK401TE	87,000	101	12.3	80%	A重油	9.9~13.2	71.0%	14.0	71.2%	13.9	71.5%	13.9	71.7%	13.8	71.9%	13.8	72.1%	13.8	72.3%	13.7		
			HK401TC	87,000	101	12.3	80%	A重油	9.9~13.2	71.0%	14.0	71.2%	13.9	71.5%	13.9	71.7%	13.8	71.9%	13.8	72.1%	13.8	72.3%	13.7		
			HK501TC	125,000	145	17.8	80%	A重油	13.2~16.5	71.0%	20.1	71.2%	20.0	71.5%	19.9	71.7%	19.9	71.9%	19.8	72.1%	19.8	72.3%	19.7		
			HK601TC	150,000	174	21.3	80%	A重油	16.5~19.8	71.0%	24.1	71.2%	24.0	71.5%	23.9	71.7%	23.9	71.9%	23.8	72.1%	23.7	72.3%	23.6		
3型	1974 (S49)	1978 (S53)	HK303TE	75,000	87.2	10.7	80%	A重油	6.6~9.9				71.5%	12.0	71.7%	11.9	71.9%	11.9	72.1%	11.9	72.3%	11.8			
			HK303TC	75,000	87.2	10.7	80%	A重油	6.6~9.9				71.5%	12.0	71.7%	11.9	71.9%	11.9	72.1%	11.9	72.3%	11.8			
			HK403TE	87,000	101	12.3	80%	A重油	9.9~13.2				71.5%	13.9	71.7%	13.8	71.9%	13.8	72.1%	13.8	72.3%	13.7			
			HK403TC	87,000	101	12.3	80%	A重油	9.9~13.2				71.5%	13.9	71.7%	13.8	71.9%	13.8	72.1%	13.8	72.3%	13.7			
現行機種 (機器熱効率 90%) へ設備更新した場合の 経年変化分 燃料消費節減率 ※同等熱出力換算									21.1%		20.9%		20.6%		20.4%		20.1%		19.9%		19.6%				