

ネポン株式会社

【ハウスオンキ 4, 5, 6型シリーズ】

2021 年度 熱効率/燃料消費量 経年変化一覽表

製品 シリーズ	製造 開始年	製造 終了年	製品型式	熱出力		燃料 消費量 (l/h)	熱効率	燃料	標準暖房 面積 (a)	備考	製造年度別 経年変化による現在の熱効率および燃料消費量														
				(kcal/h)	(kW)						1978		1979		1980		1981		1982		1983				
						%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)								
4 型 ・ 5 型	1978 (S53)	1981 (S56)	HK155SE	32,000	37.2	4.3	88.0%	A重油	3.3~4.95			78.6%	4.6	78.8%	4.6	79.0%	4.6	79.2%	4.6						
			HK155TE	32,000	37.2	4.3	88.0%	A重油	3.3~4.95				78.6%	4.6	78.8%	4.6	79.0%	4.6	79.2%	4.6					
			HK204TC	50,000	58.1	6.7	88.0%	A重油	4.95~6.6	低床タイプ			78.6%	7.3	78.8%	7.2	79.0%	7.2	79.2%	7.2					
			HK205TE	50,000	58.1	6.7	88.0%	A重油	4.95~6.6				78.6%	7.3	78.8%	7.2	79.0%	7.2	79.2%	7.2					
			HK205TC	50,000	58.1	6.7	88.0%	A重油	4.95~6.6				78.6%	7.3	78.8%	7.2	79.0%	7.2	79.2%	7.2					
			HK304TC	75,000	87.2	10.0	88.0%	A重油	6.6~9.9	低床タイプ			78.6%	10.9	78.8%	10.9	79.0%	10.8	79.2%	10.8					
			HK305SE	75,000	87.2	10.0	88.0%	A重油	6.6~9.9				78.6%	10.9	78.8%	10.9	79.0%	10.8	79.2%	10.8					
			HK305SC	75,000	87.2	10.0	88.0%	A重油	6.6~9.9				78.6%	10.9	78.8%	10.9	79.0%	10.8	79.2%	10.8					
			HK305TE	75,000	87.2	10.0	88.0%	A重油	6.6~9.9				78.6%	10.9	78.8%	10.9	79.0%	10.8	79.2%	10.8					
			HK305TC	75,000	87.2	10.0	88.0%	A重油	6.6~9.9				78.6%	10.9	78.8%	10.9	79.0%	10.8	79.2%	10.8					
			HK404TC	87,000	101	11.6	88.0%	A重油	9.9~13.2	低床タイプ			78.6%	12.6	78.8%	12.6	79.0%	12.6	79.2%	12.5					
			HK405TE	87,000	101	11.6	88.0%	A重油	9.9~13.2				78.6%	12.6	78.8%	12.6	79.0%	12.6	79.2%	12.5					
			HK405TC	87,000	101	11.6	88.0%	A重油	9.9~13.2				78.6%	12.6	78.8%	12.6	79.0%	12.6	79.2%	12.5					
HK505TC	125,000	145	16.6	88.0%	A重油	13.2~16.5				78.6%	18.1	78.8%	18.1	79.0%	18.0	79.2%	18.0								
HK605TC	150,000	174	19.9	88.0%	A重油	16.5~19.8				78.6%	21.8	78.8%	21.7	79.0%	21.6	79.2%	21.6								
6 型	1981 (S56)	1983 (S58)	HK156SE	32,000	37.2	4.2	88.0%	A重油	3.3~4.95								79.2%	4.6	79.5%	4.6	79.7%	4.6			
			HK156TE	32,000	37.2	4.2	88.0%	A重油	3.3~4.95								79.2%	4.6	79.5%	4.6	79.7%	4.6			
			HK206TE	50,000	58.1	6.5	88.0%	A重油	4.95~6.6								79.2%	7.2	79.5%	7.2	79.7%	7.2			
			HK206TC	50,000	58.1	6.5	88.0%	A重油	4.95~6.6								79.2%	7.2	79.5%	7.2	79.7%	7.2			
			HK306SE	75,000	87.2	9.7	88.0%	A重油	6.6~9.9								79.2%	10.8	79.5%	10.8	79.7%	10.7			
			HK306SC	75,000	87.2	9.7	88.0%	A重油	6.6~9.9								79.2%	10.8	79.5%	10.8	79.7%	10.7			
			HK306TE	75,000	87.2	9.7	88.0%	A重油	6.6~9.9								79.2%	10.8	79.5%	10.8	79.7%	10.7			
			HK306TC	75,000	87.2	9.7	88.0%	A重油	6.6~9.9								79.2%	10.8	79.5%	10.8	79.7%	10.7			
			HK316TC	75,000	87.2	9.7	88.0%	A重油	6.6~9.9	低床タイプ							79.2%	10.8	79.5%	10.8	79.7%	10.7			
			HK406TE	87,000	101	11.3	88.0%	A重油	9.9~13.2								79.2%	12.5	79.5%	12.5	79.7%	12.4			
			HK406TC	87,000	101	11.3	88.0%	A重油	9.9~13.2								79.2%	12.5	79.5%	12.5	79.7%	12.4			
			HK416TC	87,000	101	11.3	88.0%	A重油	9.9~13.2	低床タイプ							79.2%	12.5	79.5%	12.5	79.7%	12.4			
			HK506TC	125,000	145	16.2	88.0%	A重油	13.2~16.5								79.2%	18.0	79.5%	17.9	79.7%	17.9			
HK606TC	150,000	174	19.4	88.0%	A重油	16.5~19.8								79.2%	21.6	79.5%	21.5	79.7%	21.5						
現行機種（機器熱効率 90% ）へ設備更新した場合の 経年変化分 燃料消費節減率 ※同等熱出力換算											12.7%	12.5%	12.2%	12.0%	11.7%	11.5%									