

ネポン株式会社

【ハウスオキ 0.1,3型シリーズ】 1/2 2022 年度 熱効率/燃料消費量 経年変化一覧表

製品 シリーズ	製造 開始年	製造 終了年	製品型式	熱出力		燃料 消費量 (l/h)	熱効率	燃料	標準暖房 面積 (a)	製造年度別 経年変化による現在の熱効率および燃料消費量															
				(kcal/h)	(kW)					1965		1966		1967		1968		1969		1970		1971			
										%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)		
0型	1965 (S40)	1976 (S51)	HK150TE	32.000	37.2	4.6	80%	A重油	2.3~5.0	67.5%	5.4	67.7%	5.4	67.9%	5.4	68.2%	5.4	68.4%	5.3	68.6%	5.3	68.8%	5.3		
			HK150SE	32.000	37.2	4.6	80%	A重油	2.3~5.0	67.5%	5.4	67.7%	5.4	67.9%	5.4	68.2%	5.4	68.4%	5.3	68.6%	5.3	68.8%	5.3		
			HK300TE	75.000	87.2	10.7	80%	A重油	6.6~9.9	67.5%	12.7	67.7%	12.6	67.9%	12.6	68.2%	12.5	68.4%	12.5	68.6%	12.5	68.8%	12.4		
			HK300TC	75.000	87.2	10.7	80%	A重油	6.6~9.9	67.5%	12.7	67.7%	12.6	67.9%	12.6	68.2%	12.5	68.4%	12.5	68.6%	12.5	68.8%	12.4		
			HK300SE	75.000	87.2	10.7	80%	A重油	6.6~9.9	67.5%	12.7	67.7%	12.6	67.9%	12.6	68.2%	12.5	68.4%	12.5	68.6%	12.5	68.8%	12.4		
			HK300SC	75.000	87.2	10.7	80%	A重油	6.6~9.9	67.5%	12.7	67.7%	12.6	67.9%	12.6	68.2%	12.5	68.4%	12.5	68.6%	12.5	68.8%	12.4		
			HK400TE	87.000	101	12.3	80%	A重油	9.9~13.2	67.5%	14.7	67.7%	14.6	67.9%	14.6	68.2%	14.6	68.4%	14.5	68.6%	14.5	68.8%	14.4		
			HK400TC	87.000	101	12.3	80%	A重油	9.9~13.2	67.5%	14.7	67.7%	14.6	67.9%	14.6	68.2%	14.6	68.4%	14.5	68.6%	14.5	68.8%	14.4		
1型	1971 (S46)	1978 (S53)	HK500TC	125.000	145	17.8	80%	A重油	13.2~16.5	67.5%	21.1	67.7%	21.0	67.9%	21.0	68.2%	20.9	68.4%	20.8	68.6%	20.8	68.8%	20.7		
			HK600TC	150.000	174	21.3	80%	A重油	16.5~19.8	67.5%	25.3	67.7%	25.2	67.9%	25.2	68.2%	25.1	68.4%	25.0	68.6%	24.9	68.8%	24.8		
			HK301TE	75.000	87.2	10.7	80%	A重油	6.6~9.9														68.8%	12.4	
			HK301TC	75.000	87.2	10.7	80%	A重油	6.6~9.9															68.8%	12.4
			HK401TE	87.000	101	12.3	80%	A重油	9.9~13.2															68.8%	14.4
			HK401TC	87.000	101	12.3	80%	A重油	9.9~13.2															68.8%	14.4
			HK501TC	125.000	145	17.8	80%	A重油	13.2~16.5															68.8%	20.7
			HK601TC	150.000	174	21.3	80%	A重油	16.5~19.8															68.8%	24.8
現行機種（機器熱効率 90%）へ更新した場合の 経年変化節減率 ※同等熱出力換算									25.0%		24.8%		24.5%		24.3%		24.0%		23.8%		23.5%				

【ハウスオキ 0.1,3型シリーズ】 2/2

製品 シリーズ	製造 開始年	製造 終了年	製品型式	熱出力		燃料 消費量 (l/h)	熱効率	燃料	標準暖房 面積 (a)	製造年度別 経年変化による現在の熱効率および燃料消費量													
				(kcal/h)	(kW)					1972		1973		1974		1975		1976		1977		1978	
										%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)
0型	1965 (S40)	1976 (S51)	HK150TE	32.000	37.2	4.6	80%	A重油	2.3~5.0	69.0%	5.3	69.3%	5.3	69.5%	5.3	69.7%	5.2	69.9%	5.2				
			HK150SE	32.000	37.2	4.6	80%	A重油	2.3~5.0	69.0%	5.3	69.3%	5.3	69.5%	5.3	69.7%	5.2	69.9%	5.2				
			HK300TE	75.000	87.2	10.7	80%	A重油	6.6~9.9	69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2				
			HK300TC	75.000	87.2	10.7	80%	A重油	6.6~9.9	69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2				
			HK300SE	75.000	87.2	10.7	80%	A重油	6.6~9.9	69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2				
			HK300SC	75.000	87.2	10.7	80%	A重油	6.6~9.9	69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2				
			HK400TE	87.000	101	12.3	80%	A重油	9.9~13.2	69.0%	14.4	69.3%	14.3	69.5%	14.3	69.7%	14.2	69.9%	14.2				
			HK400TC	87.000	101	12.3	80%	A重油	9.9~13.2	69.0%	14.4	69.3%	14.3	69.5%	14.3	69.7%	14.2	69.9%	14.2				
1型	1971 (S46)	1978 (S53)	HK500TC	125.000	145	17.8	80%	A重油	13.2~16.5	69.0%	20.6	69.3%	20.6	69.5%	20.5	69.7%	20.4	69.9%	20.4				
			HK600TC	150.000	174	21.3	80%	A重油	16.5~19.8	69.0%	24.8	69.3%	24.7	69.5%	24.6	69.7%	24.5	69.9%	24.5				
			HK301TE	75.000	87.2	10.7	80%	A重油	6.6~9.9	69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2	70.1%	12.2	70.4%	12.2
			HK301TC	75.000	87.2	10.7	80%	A重油	6.6~9.9	69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2	70.1%	12.2	70.4%	12.2
			HK401TE	87.000	101	12.3	80%	A重油	9.9~13.2	69.0%	14.4	69.3%	14.3	69.5%	14.3	69.7%	14.2	69.9%	14.2	70.1%	14.1	70.4%	14.1
			HK401TC	87.000	101	12.3	80%	A重油	9.9~13.2	69.0%	14.4	69.3%	14.3	69.5%	14.3	69.7%	14.2	69.9%	14.2	70.1%	14.1	70.4%	14.1
3型	1974 (S49)	1978 (S53)	HK501TC	125.000	145	17.8	80%	A重油	13.2~16.5	69.0%	20.6	69.3%	20.6	69.5%	20.5	69.7%	20.4	69.9%	20.4	70.1%	20.3	70.4%	20.3
			HK601TC	150.000	174	21.3	80%	A重油	16.5~19.8	69.0%	24.8	69.3%	24.7	69.5%	24.6	69.7%	24.5	69.9%	24.5	70.1%	24.4	70.4%	24.3
			HK303TE	75.000	87.2	10.7	80%	A重油	6.6~9.9					69.5%	12.3	69.7%	12.3	69.9%	12.2	70.1%	12.2	70.4%	12.2
			HK303TC	75.000	87.2	10.7	80%	A重油	6.6~9.9					69.5%	12.3	69.7%	12.3	69.9%	12.2	70.1%	12.2	70.4%	12.2
3型	1974 (S49)	1978 (S53)	HK403TE	87.000	101	12.3	80%	A重油	9.9~13.2					69.5%	14.3	69.7%	14.2	69.9%	14.2	70.1%	14.1	70.4%	14.1
			HK403TC	87.000	101	12.3	80%	A重油	9.9~13.2					69.5%	14.3	69.7%	14.2	69.9%	14.2	70.1%	14.1	70.4%	14.1
現行機種（機器熱効率 90%）へ設備更新した場合の 経年変化分 燃料消費節減率 ※同等熱出力換算									23.3%		23.0%		22.8%		22.6%		22.3%		22.1%		21.8%		