

ネポン株式会社

【ハウスオンキ 4, 5, 6型シリーズ】

2022 年度 熱効率/燃料消費量 経年変化一覧表

製品 シリーズ	製造 開始年	製造 終了年	製品型式	熱出力		燃料 消費量 (l/h)	熱効率	燃料	標準暖房 面積 (a)	備考	製造年度別 経年変化による現在の熱効率および燃料消費量													
				(kcal/h)	(kW)						1978		1979		1980		1981		1982		1983			
											%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)		
4 型 ・ 5 型	1978 (S53)	1981 (S56)	HK155SE	32,000	37.2	4.3	88.0%	A 重油	3.3~4.95			78.4%	4.7	78.6%	4.6	78.8%	4.6	79.0%	4.6					
			HK155TE	32,000	37.2	4.3	88.0%	A 重油	3.3~4.95				78.4%	4.7	78.6%	4.6	78.8%	4.6	79.0%	4.6				
			HK204TC	50,000	58.1	6.7	88.0%	A 重油	4.95~6.6	低床タイプ			78.4%	7.3	78.6%	7.3	78.8%	7.2	79.0%	7.2				
			HK205TE	50,000	58.1	6.7	88.0%	A 重油	4.95~6.6				78.4%	7.3	78.6%	7.3	78.8%	7.2	79.0%	7.2				
			HK205TC	50,000	58.1	6.7	88.0%	A 重油	4.95~6.6				78.4%	7.3	78.6%	7.3	78.8%	7.2	79.0%	7.2				
			HK304TC	75,000	87.2	10.0	88.0%	A 重油	6.6~9.9	低床タイプ			78.4%	10.9	78.6%	10.9	78.8%	10.9	79.0%	10.8				
			HK305SE	75,000	87.2	10.0	88.0%	A 重油	6.6~9.9				78.4%	10.9	78.6%	10.9	78.8%	10.9	79.0%	10.8				
			HK305SC	75,000	87.2	10.0	88.0%	A 重油	6.6~9.9				78.4%	10.9	78.6%	10.9	78.8%	10.9	79.0%	10.8				
			HK305TE	75,000	87.2	10.0	88.0%	A 重油	6.6~9.9				78.4%	10.9	78.6%	10.9	78.8%	10.9	79.0%	10.8				
			HK305TC	75,000	87.2	10.0	88.0%	A 重油	6.6~9.9				78.4%	10.9	78.6%	10.9	78.8%	10.9	79.0%	10.8				
			HK404TC	87,000	101	11.6	88.0%	A 重油	9.9~13.2	低床タイプ			78.4%	12.7	78.6%	12.6	78.8%	12.6	79.0%	12.6				
			HK405TE	87,000	101	11.6	88.0%	A 重油	9.9~13.2				78.4%	12.7	78.6%	12.6	78.8%	12.6	79.0%	12.6				
			HK405TC	87,000	101	11.6	88.0%	A 重油	9.9~13.2				78.4%	12.7	78.6%	12.6	78.8%	12.6	79.0%	12.6				
HK505TC	125,000	145	16.6	88.0%	A 重油	13.2~16.5				78.4%	18.2	78.6%	18.1	78.8%	18.1	79.0%	18.0							
HK605TC	150,000	174	19.9	88.0%	A 重油	16.5~19.8				78.4%	21.8	78.6%	21.8	78.8%	21.7	79.0%	21.6							
6 型	1981 (S56)	1983 (S58)	HK156SE	32,000	37.2	4.2	88.0%	A 重油	3.3~4.95								79.0%	4.6	79.2%	4.6	79.5%	4.6		
			HK156TE	32,000	37.2	4.2	88.0%	A 重油	3.3~4.95									79.0%	4.6	79.2%	4.6	79.5%	4.6	
			HK206TE	50,000	58.1	6.5	88.0%	A 重油	4.95~6.6									79.0%	7.2	79.2%	7.2	79.5%	7.2	
			HK206TC	50,000	58.1	6.5	88.0%	A 重油	4.95~6.6									79.0%	7.2	79.2%	7.2	79.5%	7.2	
			HK306SE	75,000	87.2	9.7	88.0%	A 重油	6.6~9.9									79.0%	10.8	79.2%	10.8	79.5%	10.8	
			HK306SC	75,000	87.2	9.7	88.0%	A 重油	6.6~9.9									79.0%	10.8	79.2%	10.8	79.5%	10.8	
			HK306TE	75,000	87.2	9.7	88.0%	A 重油	6.6~9.9									79.0%	10.8	79.2%	10.8	79.5%	10.8	
			HK306TC	75,000	87.2	9.7	88.0%	A 重油	6.6~9.9									79.0%	10.8	79.2%	10.8	79.5%	10.8	
			HK316TC	75,000	87.2	9.7	88.0%	A 重油	6.6~9.9	低床タイプ								79.0%	10.8	79.2%	10.8	79.5%	10.8	
			HK406TE	87,000	101	11.3	88.0%	A 重油	9.9~13.2									79.0%	12.6	79.2%	12.5	79.5%	12.5	
			HK406TC	87,000	101	11.3	88.0%	A 重油	9.9~13.2									79.0%	12.6	79.2%	12.5	79.5%	12.5	
			HK416TC	87,000	101	11.3	88.0%	A 重油	9.9~13.2	低床タイプ								79.0%	12.6	79.2%	12.5	79.5%	12.5	
			HK506TC	125,000	145	16.2	88.0%	A 重油	13.2~16.5									79.0%	18.0	79.2%	18.0	79.5%	17.9	
HK606TC	150,000	174	19.4	88.0%	A 重油	16.5~19.8									79.0%	21.6	79.2%	21.6	79.5%	21.5				
現行機種（機器熱効率 90%）へ設備更新した場合の 経年変化分 燃料消費節減率 ※同等熱出力換算											12.9%	12.7%	12.5%	12.2%	12.0%	11.7%								