

ネボン株式会社

【ハウスカナンキ 0.1, 3型シリーズ】 1/2 2024 年度 熱効率/燃料消費量 経年変化一覧表

製品 シリーズ	製造 開始年	製造 終了年	製品型式	熱出力		燃料 消費量 (l/h)	熱効率	燃料	標準暖房 面積 (a)	製造年度別 経年変化による現在の熱効率および燃料消費量															
				(kcal/h)	(kW)					1965		1966		1967		1968		1969		1970		1971			
										%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)		
0型	1965 (S40)	1976 (S51)	HK150TE	32,000	37.2	4.6	80%	A重油	2.3~5.0	67.1%	5.4	67.3%	5.4	67.5%	5.4	67.7%	5.4	67.9%	5.4	68.2%	5.4	68.4%	5.3		
			HK150SE	32,000	37.2	4.6	80%	A重油	2.3~5.0	67.1%	5.4	67.3%	5.4	67.5%	5.4	67.7%	5.4	67.9%	5.4	68.2%	5.4	68.4%	5.3		
			HK300TE	75,000	87.2	10.7	80%	A重油	6.6~9.9	67.1%	12.7	67.3%	12.7	67.5%	12.7	67.7%	12.6	67.9%	12.6	68.2%	12.5	68.4%	12.5		
			HK300TC	75,000	87.2	10.7	80%	A重油	6.6~9.9	67.1%	12.7	67.3%	12.7	67.5%	12.7	67.7%	12.6	67.9%	12.6	68.2%	12.5	68.4%	12.5		
			HK300SE	75,000	87.2	10.7	80%	A重油	6.6~9.9	67.1%	12.7	67.3%	12.7	67.5%	12.7	67.7%	12.6	67.9%	12.6	68.2%	12.5	68.4%	12.5		
			HK300SC	75,000	87.2	10.7	80%	A重油	6.6~9.9	67.1%	12.7	67.3%	12.7	67.5%	12.7	67.7%	12.6	67.9%	12.6	68.2%	12.5	68.4%	12.5		
			HK400TE	87,000	101	12.3	80%	A重油	9.9~13.2	67.1%	14.8	67.3%	14.7	67.5%	14.7	67.7%	14.6	67.9%	14.6	68.2%	14.6	68.4%	14.5		
			HK400TC	87,000	101	12.3	80%	A重油	9.9~13.2	67.1%	14.8	67.3%	14.7	67.5%	14.7	67.7%	14.6	67.9%	14.6	68.2%	14.6	68.4%	14.5		
1型	1971 (S46)	1978 (S53)	HK500TC	125,000	145	17.8	80%	A重油	13.2~16.5	67.1%	21.2	67.3%	21.2	67.5%	21.1	67.7%	21.0	67.9%	21.0	68.2%	20.9	68.4%	20.8		
			HK600TC	150,000	174	21.3	80%	A重油	16.5~19.8	67.1%	25.5	67.3%	25.4	67.5%	25.3	67.7%	25.2	67.9%	25.2	68.2%	25.1	68.4%	25.0		
			HK301TE	75,000	87.2	10.7	80%	A重油	6.6~9.9														68.4%	12.5	
			HK301TC	75,000	87.2	10.7	80%	A重油	6.6~9.9															68.4%	12.5
			HK401TE	87,000	101	12.3	80%	A重油	9.9~13.2															68.4%	14.5
			HK401TC	87,000	101	12.3	80%	A重油	9.9~13.2															68.4%	14.5
現行機種HK30型（機器熱効率 90%）へ更新した場合の 経年変化節減率 ※同等熱出力換算									25.5%		25.2%		25.0%		24.8%		24.5%		24.3%		24.0%				

【ハウスカナンキ 0.1, 3型シリーズ】 2/2

製品 シリーズ	製造 開始年	製造 終了年	製品型式	熱出力		燃料 消費量 (l/h)	熱効率	燃料	標準暖房 面積 (a)	製造年度別 経年変化による現在の熱効率および燃料消費量													
				(kcal/h)	(kW)					1972		1973		1974		1975		1976		1977		1978	
										%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)	%	(l/h)
0型	1965 (S40)	1976 (S51)	HK150TE	32,000	37.2	4.6	80%	A重油	2.3~5.0	68.6%	5.3	68.8%	5.3	69.0%	5.3	69.3%	5.3	69.5%	5.3				
			HK150SE	32,000	37.2	4.6	80%	A重油	2.3~5.0	68.6%	5.3	68.8%	5.3	69.0%	5.3	69.3%	5.3	69.5%	5.3				
			HK300TE	75,000	87.2	10.7	80%	A重油	6.6~9.9	68.6%	12.5	68.8%	12.4	69.0%	12.4	69.3%	12.3	69.5%	12.3				
			HK300TC	75,000	87.2	10.7	80%	A重油	6.6~9.9	68.6%	12.5	68.8%	12.4	69.0%	12.4	69.3%	12.3	69.5%	12.3				
			HK300SE	75,000	87.2	10.7	80%	A重油	6.6~9.9	68.6%	12.5	68.8%	12.4	69.0%	12.4	69.3%	12.3	69.5%	12.3				
			HK300SC	75,000	87.2	10.7	80%	A重油	6.6~9.9	68.6%	12.5	68.8%	12.4	69.0%	12.4	69.3%	12.3	69.5%	12.3				
			HK400TE	87,000	101	12.3	80%	A重油	9.9~13.2	68.6%	14.5	68.8%	14.4	69.0%	14.4	69.3%	14.3	69.5%	14.3				
			HK400TC	87,000	101	12.3	80%	A重油	9.9~13.2	68.6%	14.5	68.8%	14.4	69.0%	14.4	69.3%	14.3	69.5%	14.3				
1型	1971 (S46)	1978 (S53)	HK500TC	125,000	145	17.8	80%	A重油	13.2~16.5	68.6%	20.8	68.8%	20.7	69.0%	20.6	69.3%	20.6	69.5%	20.5				
			HK601TC	150,000	174	21.3	80%	A重油	16.5~19.8	68.6%	24.9	68.8%	24.8	69.0%	24.8	69.3%	24.7	69.5%	24.6				
			HK301TE	75,000	87.2	10.7	80%	A重油	6.6~9.9	68.6%	12.5	68.8%	12.4	69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2
			HK301TC	75,000	87.2	10.7	80%	A重油	6.6~9.9	68.6%	12.5	68.8%	12.4	69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2
			HK401TE	87,000	101	12.3	80%	A重油	9.9~13.2	68.6%	14.5	68.8%	14.4	69.0%	14.4	69.3%	14.3	69.5%	14.3	69.7%	14.2	69.9%	14.2
			HK401TC	87,000	101	12.3	80%	A重油	9.9~13.2	68.6%	14.5	68.8%	14.4	69.0%	14.4	69.3%	14.3	69.5%	14.3	69.7%	14.2	69.9%	14.2
3型	1974 (S49)	1978 (S53)	HK501TC	125,000	145	17.8	80%	A重油	13.2~16.5	68.6%	20.8	68.8%	20.7	69.0%	20.6	69.3%	20.6	69.5%	20.5	69.7%	20.4	69.9%	20.4
			HK601TC	150,000	174	21.3	80%	A重油	16.5~19.8	68.6%	24.9	68.8%	24.8	69.0%	24.8	69.3%	24.7	69.5%	24.6	69.7%	24.5	69.9%	24.5
			HK303TE	75,000	87.2	10.7	80%	A重油	6.6~9.9					69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2
			HK303TC	75,000	87.2	10.7	80%	A重油	6.6~9.9					69.0%	12.4	69.3%	12.3	69.5%	12.3	69.7%	12.3	69.9%	12.2
現行機種HK30型（機器熱効率 90%）へ設備更新した場合の 経年変化節減率 ※同等熱出力換算									23.8%		23.5%		23.3%		23.0%		22.8%		22.6%		22.3%		