

【ハウスカオンキ 29V型シリーズ】2026 年度 熱効率率/燃料消費量 経年変化一覧表

製品 シリーズ	製造 開始年	製造 終了年	製品型式	熱出力		燃料 消費量 (l/h)	熱効率	燃料	標準暖房 面積 (a)	備考	製造年度別 経年変化による現在の熱効率および燃料消費量 ※1															
											2024		2025													
				(kcal/h)	(kW)						%	(l/h)	%	(l/h)												
29V型	2024 (R6)		HK2029TCV	50,000	58.1	6.3	90.0%	A 重油	4.95～6.6		89.6%	6.4	89.8%	6.3												
			HK2029TEV	50,000	58.1	6.3	90.0%	A 重油	4.95～6.6		89.6%	6.4	89.8%	6.3												
			HK3029TCV	75,000	87.2	9.5	90.0%	A 重油	6.6～9.9		89.6%	9.5	89.8%	9.5												
			HK3029TEV	75,000	87.2	9.5	90.0%	A 重油	6.6～9.9		89.6%	9.5	89.8%	9.5												
			HK3029TFV	75,000	87.2	9.5	90.0%	A 重油	6.6～9.9				89.8%	9.5												
			HK4029TCV	100,000	116	12.6	90.0%	A 重油	9.9～13.2		89.6%	12.7	89.8%	12.7												
			HK4029TEV	100,000	116	12.6	90.0%	A 重油	9.9～13.2		89.6%	12.7	89.8%	12.7												
			HK4029TFV	100,000	116	12.6	90.0%	A 重油	9.9～13.2				89.8%	12.7												
			HK5029TCV	125,000	145	15.8	90.0%	A 重油	13.2～16.5				89.8%	15.9												
			HK5029TEV	125,000	145	15.8	90.0%	A 重油	13.2～16.5				89.8%	15.9												
			HK5029TFV	125,000	145	15.8	90.0%	A 重油	13.2～16.5				89.8%	15.9												
			HK6029TCV	150,000	174	19.0	90.0%	A 重油	16.5～19.8				89.8%	19.0												
			HK6029TEV	150,000	174	19.0	90.0%	A 重油	16.5～19.8				89.8%	19.0												
			HK6029TFV	150,000	174	19.0	90.0%	A 重油	16.5～19.8				89.8%	19.0												
2026年度製造HK30型・29型（機器熱効率 90% ）へ設備更新した場合の 経年変化節減率 ※同等熱出力換算											0.5%		0.2%													

※1 製造年度を使用開始年度とみなし、毎年一定の使用期間がある場合の経年変化目安とする